This drawing is the property of Waterman Infrastructure & Environment Limited, and the drawing is issued on the condition that it is not copied reproduced, retained or disclosed any unauthorised person, either wholly or in part without the consent in writing of Waterman Infrastructure & Environment Limited, Pickfords Wharf, Clinic Street, London SE1 9DG 1020 7928 7888 f 03333 444 501

**GENERAL NOTES** 

COX'S WALK FOOTBRIDGE

PEXISTING ABUTMENT WALLS TO BE
DEMOLISHED TO GROUND LEVEL ONLY
AND REBUILT. BACKFILL TO BE REPLACED
WITH FOAM CONCRETE OR SIMILAR

NEW STEEL FRAME
SUPPORT TO THE ENDS OF
THE STRUCTURE

SUPPORTED ON RC PILE CAP AND SCREW PILES

REFURBISHMENT WORKS





Crown House 2 - 8 Gloucester Road Redhill Surrey RH1 1FH t 01342 893800 f 03333 444 501
mail@watermangroup.com www.watermangroup.com

PRELIMINARY					
Designed By	JMF	Checked By	TA	Waterman Ref	WIE16887-126
Drawn By	СТ	Date	MAY 2022	Scales @ A1	AS SHOWN
Project - Originator - Volume - Level - Type - Role - Number Revision					

16887-126-WIE-ZZ-XX-DR-C-04001

A1-Wat-BS-S

P01

CLOCALISED AREAS OF EXPOSED REINFORCEMENT TO BE CLEANED AND SPALLED CONCRETE TO THE SLAB SOFFIT TO BE REPAIRED

SOUTHERN ELEVATION

BRICKWORK REPAIRS,
CLEANING AND
ANTI-GRAFFITI TREATMENT
TO THE PIERS

SCALE 1:60

-EXISTING TIMBER FRAME SUPPORTING PARAPET TO BE REPLACED. ALTERNATIVE MATERIALS

TO BE REVIEWED TO IMPROVE DURABILITY

-CORRODED STEEL BEAMS TO BE BLAST CLEANED AND REPAINTED USING FEVE COATING SYSTEM OR

ADJUST GROUND LEVELS— TO SUIT THE NEW WORKS TO THE ABUTMENTS AND THE EXISTING PIERS

EXISTING ABUTMENT WALLS TO BE-DEMOLISHED TO GROUND LEVEL ONLY AND REBUILT. BACKFILL TO BE REPLACED WITH FOAM CONCRETE OR SIMILAR

NEW STEEL FRAME— SUPPORT TO THE ENDS OF THE STRUCTURE SUPPORTED ON RC PILE CAP AND SCREW PILES

EXISTING PARAPET PANELS

TO BE TEMPORARILY REMOVED, REFURBISHED

AND REUSED IF POSSIBLE